# Fieldbus system

# **Instruction Manual**

# **EX600-SEN7/EX600-SEN8**

EtherNet/IP

Thank you for purchasing an SMC EX600 Series Fieldbus system

Please read this manual carefully before operating the product and make sure you understand its capabilities and limitations.

Please keep this manual handy for future reference.

To obtain more detailed information about operating this product, please refer to the SMC website (URL https://www.smcworld.com) or contact SMC directly.

# **Safety Instructions**

These safety instructions are intended to prevent hazardous situations and/or equipment damage.

These instructions indicate the level of potential hazard with the labels of "Caution", "Warning" or "Danger". They are all important notes for safety and must be followed in addition to International standards (ISO/IEC) and other safety regulations.


CAUTION indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.

WARNING indicates a hazard with a medium level of risk Warning: Which, if not avoided, could result in death or serious injury.

⚠ Danger: DANGER indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

### Operator

- ◆ The operation manual is intended for those who have knowledge of machinery using pneumatic equipment, and have sufficient knowledge of assembly operation and maintenance of such equipment. Only those persons are allowed to perform assembly, operation and maintenance.
- ◆ Read and understand the operation manual carefully before assembling, operating or providing maintenance to the product.



**Summary of Product parts** 



No.	Description	Function		
1	Status display LED	Displays the status of the unit.		
2	Display cover	Open at the switch configuration.		
3	Connector (PORT2)	Connector for the fieldbus communication cable.		
4	Marker groove	Groove for an identification marker.		
5	MAC address label	Displays the 12 digit MAC address which is different for each SI unit.		
6	Valve plate mounting hole	Holes for fixing the valve plate.		
7	Valve plate mounting groove	Groove for mounting the valve plate.		
8	Joint bracket	Bracket for joining to adjacent units.		
9	Unit connector (Plug)	Connector for signals and power supplies to adjacent units.		
10	Connector (PORT1)	Connector for the fieldbus communication cable.		
11	Seal cap	Fitted to unused connector. (PORT2)		

# Assembly

#### OAssembling the unit as a manifold

(1)Connect a unit to the end plate.
Digital and Analogue I/O units can be connected in any

Tighten the joint brackets to a torque of 1.5 to 1.6 N•m.

(2)Add more I/O units.

Up to 10 units (including the SI unit) can be connected to one manifold.


(3)Connecting the SI unit. After connecting the required I/O units, connect the SI unit.

The method is as above in (1), (2).

Fix using the valve plate screws

(M4 x 6) supplied, to a torque of 0.7 to

(4)Mounting the valve plate Mount the valve plate (EX600–ZMV#) to the valve manifold using the valve set screws. (M3 x 8) Apply 0.6 to 0.7 N·m tightening torque to the screws





#### (5)Connect the SI unit to the valve manifold Insert the valve plate into the valve plate mounting groove on the side of **⚠** Warning the SI unit.

■ Do not operate the product outside of the specifications Do not use for flammable or harmful fluids. Fire, malfunction, or damage to the product can result Verify the specifications before use.

■Do not operate in an atmosphere containing flammable or explosive gases. Fire or an explosion can result.

■ Do not disassemble, modify (including changing the printed circuit board) or repair. An injury or failure can result.

This product is not designed to be explosion proof.

**■**Safety Instructions

■If using the product in an interlocking circuit:
•Provide a double interlocking system, for example a mechanical system Check the product regularly for proper operation

Otherwise malfunction can result, causing an accident

■ The following instructions must be followed during maintenance:

- Turn off the power supply

- Stop the air supply, exhaust the residual pressure and verify that the air is released before performing

Otherwise an injury can result

### **△** Caution

■ When handling, assembling or replacing the units:

• Avoid touching any sharp metal parts of the connectors for connecting units.

• When assembling units, take care not to get any fingers caught between units. Iniury can result.

•When disassembling units, take care to avoid excessive force

The connection parts of the unit are firmly joined with seals and injury can result.

After maintenance is complete, perform appropriate functional inspections Stop operation if the equipment does not function properly. Safety cannot be assured in the case of unexpected malfunction.

■ Provide grounding to assure the noise resistance of the Fieldbus system. Individual grounding should be provided close to the product with a short cable

#### **■NOTE**

- •The direct current power supply to combine should be UL1310 Class 2 power supply when conformity to UL is necessary.
- •The output rating is tested as a DC output for General use.

#### Maintenance

•Maintenance should be performed according to the Safety Instructions.

Perform regular maintenance and inspections There is a risk of unexpected malfunction.

•Do not use solvents such as benzene, thinner etc. to clean each unit.

They could damage the surface of the body and erase the markings on the body. Use a soft cloth to remove stains.

For heavy stains, use a cloth soaked with diluted neutral detergent and fully squeezed, then wipe up

Refer to the SMC website (URL https://www.smcworld.com) for more information about maintenance

# Mounting and Installation

### ■Installation

•Direct mounting (1)When joining six or more units, fix the middle part of the complete EX600 unit with an intermediate reinforcing brace (EX600-ZMB1) before mounting, using 2-M4 x 5 screws. Tightening torque: 0.7 to 0.8 N•m.

(2)Mount and tighten the end plate at one end of the unit. (M4) Tightening torque: 0.7 to 0.8 N•m.
Fix the end plate at the valve side while

referring to the operation manual of the corresponding valve manifold.

•DIN rail mounting (Not available for SY series valves. Refer to the SY catalogue.) (1)When joining six or more units, fix the

middle part of the complete EX600 unit with an intermediate reinforcing brace (EX600-ZMB2) before mounting, using Tightening torque: 0.7 to 0.8 N•m.

(2)Mount the end plate bracket (EX600-ZMA2) to the end plate at the opposite end to the valves, using 2-M4 x 14 Tightening torque: 0.7 to 0.8 N•m.



Intermediate reinforcing brace

Intermediate reinforcing brace


(EX600-ZMB1)

(EX600-ZMB2)

(3)Hook the DIN rail mounting groove on to the



(4)Press the manifold using its side hooked to the DIN rail as a fulcrum until the manifold is



# **Setting and Adjustment**

(5)Fix the manifold by tightening the DIN rail fixing

PORT2

The signal name of the input or output devices and unit address can be written to the marker, and can be

Mount the marker (EX600-ZT1) into the marker groove

End plate bracket

(EX600-ZMA2)

RX+

screws of the EX600-ZMA2. (M4 x 20) Tightening torque: 0.7 to 0.8 N•m. The tightening torque at the valve side depends

Refer to the operation manual of the

corresponding valve manifold.

on the valve type.

Connector pin assignment

■Wiring

PORT1

Mounting the marker

installed to each unit.

as required.



#### IP address setting switch

Settings1	Settings2					IP address			
8	1	2	3	4	5	6	7	8	ir address
OFF	ON	OFF	OFF	OFF	OFF	OFF	OFF	OFF	192.168.0.1
:	:	:	:	:	:	:	:	:	:
OFF	OFF	ON	ON	ON	ON	ON	ON	ON	192.168.0.254
ON	ON	OFF	OFF	OFF	OFF	OFF	OFF	OFF	192.168.1.1
:	:	:	:	:	:	:	:	:	:
ON	OFF	ON	ON	ON	ON	ON	ON	ON	192.168.1.254
ON/OFF	ON	ON	ON	ON	ON	ON	ON	ON	DHCP mode
ON/OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Remote Control mode

•HOLD/CLEAR setting switch: Sets the output status when the fieldbus has a communication error or is in idling state

Settings1	Content			
1				
OFF	Output is OFF. (default setting)			
ON	Holds the output.			
*: This switch can be enabled and disabled by parameter				

Diagnostic mode setting switch: Allocates the diagnostic data to the input data.

Settings1	Mode	Content	Diagnostic size set for the input	
3	Would	Content		
OFF	0	Input data only (default setting)	0 byte	
ON	1	Input data + System diagnosis + Unit diagnosis	4 byte	


•IO size setting switch for IO-Link unit: IO size of IO-Link unit is selected by setting switch.

Setti	ngs1	IO size	
4	5		
OFF	OFF	44 byte	
OFF ON		70 byte	
ON	OFF	134 byte	
ON	ON	134 byte	

Refer to the SMC website (URL https://www.smcworld.com) for more information about setting and adjustment

# **LED Display**

The status display LED displays the power supply and communication status



LED display	Content				
	Green ON	Normal operation.			
	Green flashing	Diagnostic error of I/O unit is detected.			
ST(M)	Red flashing	Any of the following diagnostic error is detected. (When diagnostic parameter is enabled)  "Valve ON/OFF counter has exceeded the set value.  "Valve is short circuited or disconnected.  "O-Link mapping oversize error detected.			
	Red/green flashing	Internal communication error between SI unit and I/O unit is detected.			
	Red ON	SI unit has failed.			
	Green ON	The power supply voltage for control and input is properly.			
PWR	Red ON	The power supply voltage for control and input is below 19 VDC. (When diagnostic parameter is enabled)			
	OFF The power supply voltage for output is below 19 VDC. (When diagnostic parameter is disabled)				
PWR(V)	Green ON	The power supply for output is properly.			
	Red ON	The power supply voltage for output is below 19 VDC. (When diagnostic parameter is enabled)			
	Green flashing  Either of the following conditions are detected:  -The unit has not been configured correctly.  -The PLC is idle state.				
MS	Green ON	Normal operation.			
	Red flashing	Diagnostic error is detected.			
	Red ON	The element in SI unit is broken.			
	OFF	IP address is not set.			
	Green flashing	EtherNet/IP™ communication is not established.			
NS	Green ON	EtherNet/IP™ communication is established.			
	Red flashing	EtherNet/IP™ communication is time-out.			
	Red ON	IP address is duplicated.			
	OFF	No Link, No Activity			
	Green ON	Link, No Activity (100 Mbps)			
L/A PORT1	Green flashing	Link, Activity (100 Mbps)			
	Yellow ON	Link, No Activity (10 Mbps)			
	Yellow flashing	Link, Activity(10 Mbps)			
	OFF	No Link, No Activity			
	Green ON	Link, No Activity (100 Mbps)			
L/A PORT2	Green flashing	Link, Activity (100 Mbps)			
	Yellow ON	Link, No Activity (10 Mbps)			
	Yellow flashing	Link, Activity (10 Mbps)			

about LED state.

# **Troubleshooting**

Refer to the LED Display. Refer to the SMC website (URL https://www.smcworld.com) for more information about troubleshooting.

### **Specifications**

Model		FX600-SFN7	EX600-SEN8			
	Protocol	EtherNet/IP <sup>TM</sup>				
Communication	Conformance version	CT18				
	Communiaction speed	10/100 Mbps				
	Configuration file	EDS file				
		QuickConnect™				
	Application function	DLR Web server				
=	Power supply for Control/Input	24 VDC C	lass 2, 2 A			
ectrical	Power supply for Output	24 VDC Class 2, 2 A				
Elect	Internal current consumption (Power supply for Control/Input)	120 mA or less				
	Output type	Source/PNP (Negative common)	Sink/NPN (Positive common)			
	Number of outputs	32 ou	itputs			
Output	Connected load and output rating	Solenoid valve with surge voltage suppressor of 24 VDC, 1.0 W or less, DC General per output (manufactured by SMC)				
	Fail safe	Hold/Clear/Forced ON				
	Protection	Short circuit protection				
Or	perating temperature	-10 to 50 °C (Max. surrounding air temeprature rating: 50 °C)				
Vibration resistance		10 to 57 Hz constant amplitude 0.75 mm p-p 57 to 150 Hz constant acceleration 49 m/s <sup>2</sup> for 2 hours each in direction X, Y and Z respectively (De-energized)				
Impact resistance		147 m/s <sup>2</sup> 3 times each in direction of X, Y and Z respectively (De-energized)				
En	closure	IP67 (Manifold assembly) (IP rating is outside range for UL/cUL certified)				
Sta	andard	CE/UKCA marked, UL (CSA)				
W	eight	300 g				

Refer to the product catalogue or SMC website (URL https://www.smcworld.com)

# **Outline with Dimensions**

Refer to the product catalogue or SMC website (URL https://www.smcworld.com) for more information about outline dimensions.

SMC Corporation URL https://www.smcworld.com

Akihabara UDX 15F, 4-14-1, Sotokanda, Chiyoda-ku, Tokyo 101-0021, JAPAN

Phone: +81 3-5207-8249 Fax: +81 3-5298-5362

Note: Specifications are subject to change without prior notice and any obligation on the part of the manufacturer © 2021 SMC Corporation All Rights Reserved EX\*\*-OM.